



Wels-Thalheim, 26.05.2008

Document of Compliance 08014

Product: Automatic switching center

Type: Fronius IG Plus, Setup DE, FRA, AUT, GRE, POR, EXC

Intended Use:

Automatic switching center inaccessible to the DSO as a safety interface between an in-plant generation system and the low-voltage grid. Also a backup for a switching center always accessible to the DSO with an isolation function. The switching center is an integral of the PV inverter type : Fronius IG Plus

Test specification:

DIN V VDE 0126-1-1: 2006-02

Automatic switching center between a parallel net generation system and the public low-voltage grid.

The safety concept of the above product tested with the report of 02.07.2007 ref. 2.04.00403.1.0 (arsenal research) corresponds to the safety requirements for the intended purpose valid at the time this certificate was issued.

This document of compliance is valid until:

31.12.2012

FRONIUS INTERNATIONAL GMBH
Günter-Fronius-Straße 1
4600 Thalheim/Wels

A handwritten signature in blue ink, appearing to read "ppa Hackl".

ppa Mag. Ing. H. Hackl